



		5		6	
<ul style="list-style-type: none"> <li>● DESIGN STANDARD :- API609   IS13095   BS5155</li> <li>● TESTING STANDARD :- API598</li> <li>● FACE TO FACE STANDARD :- API609   IS13095   BS5155</li> <li>● END CONNECTION :- Wafer to suite ANSI 150 Class, BS Table D &amp; E IDIN PN 10 &amp; 16</li> </ul>					
		HYDRD TEST PRESSURE			
PRESSURE RATING		PN 10			
BODY TEST		15 Kg/cm <sup>2</sup>			
SEAT TEST		11 Kg/cm <sup>2</sup>			
		NOTES / REMARKS			
		1) PCD of valves to be specified by buyer & we shall confirm it's feasibility for the same. 2) By default tapped hole are provided, please mention tapping size clearly in Purchase Order.			
13	BOTTOM PACKING	EPDM		1	
12	BOTTOM PAD	M.S.	S.S.	1	
11	BOTTOM PAD BOLT	M.S.	S.S.	3	
10	BOLT	M.S.	S.S.	4	
9	HANDLE WHEEL	M.S. Fabricated		1	
8	BUSH	SS 304 WITH PTFE		2	
7	O-RING	EPDM		2	
6	GEAR BOX	Cast Iron Housing		1	
5	PIN	SS 410 / 304 / 316 / Special Metals		1	
4	SHAFT	SS 410 / 304 / 316 / Special Metals		1	
3	SEAT	EPDM / Nitrile / Neoprene / Silicon / Viton / Hypalon		1	
2	DISC	SGI / CI / WCB	CF8 / CF8M / Special Metals	1	
1	BODY	SGI / CI / WCB	CF8 / CF8M / Special Metals	1	
NO.	DESCRIPTION	MATERIAL		QTY.	
All dimensions are in mm				APP.	MINESH
Scale:- Not to scale				DATE	20-3-2021
TITLE :- Wafer Type Centric Disc Replaceable Seat Butterfly Valve G.D.				CHK.	MINESH
				DATE	19-03-2021
				DRN	MASUM
DRG. NO. :- BFV-WAF-REP-GO-450				DATE	18-03-2021
<h2 style="margin: 0;">SHREENATH ENGINEERING</h2> <p style="margin: 0;">MOBILE :- +91 9825530462, 9979082211</p> <p style="margin: 0;">E-mail : <a href="mailto:neconvalves@yahoo.com">neconvalves@yahoo.com</a></p> <p style="margin: 0;">Website : <a href="http://www.neconvalves.com">www.neconvalves.com</a></p>					
R3				PROJECT :-	DATE:-
R2				CUSTOMER :-	
R1	Updated Layout and Dimensions	MINESH	05/01/2022	INQUIRY NO :-	
REV.	DESCRIPTION	APP.BY	DATE	P.O. NO. :-	
We reserve all rights to make any changes due to continuous improvement in process without any prior notice.					